



CERTIFICATION MARK

This certifies that

GLOBAL WATER SOLUTIONS LTD.

has had the undermentioned product examined, tested and found, when correctly installed, to comply with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations and Scottish Water Byelaws.

EXPANSION VESSELS:

MTRA & PTRA MODELS - MAXIMUM WORKING PRESSURE 7.0 BAR
MTPA, STPA, STPB, MTPB & MTPE MODELS - MAXIMUM WORKING PRESSURE 10.0 BAR
MTMA, MTMB & STMB MODELS - MAXIMUM WORKING PRESSURE 16.0 BAR
MTUA & MTUB MODELS - MAXIMUM WORKING PRESSURE 25.0 BAR
(FOR SPECIFIC MODELS COVERED PLEASE SEE WRAS DIRECTORY LISTING)

The certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Directory (www.wras.co.uk/directory)

The product so mentioned will be valid until the end of:

May 2020

1505042

Certificate No.

A handwritten signature in black ink, appearing to read 'Hurns', written over a horizontal line.

Secretary

A handwritten signature in black ink, appearing to read 'K. Husby', written over a horizontal line.

Chairman, Product Assessment Group